

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1842

Dated:30/04/25

It is certified that an inspection team headed by MR SUSHANT RANJAN ( A.En. PHED) (Name of Officers with designation) from PHED inspected the TAGORE PUBLIC SENIOR SECONDARY SCHOOL, V/PO.-OSIAN, DIST.-JODHPUR (RAJ.) (Name & Address of the school) on 05/05/25 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 70/20/03/25 dated 20/03/25 Of Office of the sup. Chemist. Lab (PHED Lab) certified that the TAGORE PUBLIC SENIOR SECONDARY SCHOOL ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 30/04/26

Signature with Seal: *Sushant Ranjan*  
Assistant Engineer  
PHED Division Osian  
Name : *Sushant Ranjan*  
Designation : *Assistant Engineer*  
Name & Address of the Office / Department : *Public health Engineering Department*

To  
TAGORE PUB.SR. SEC. SCHOOL  
V/PO.-OSIAN, DIST.-JODHPUR (RAJ.)  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



OFFICE OF THE JUNIOR CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT. LABORATORY JODHPUR  
REPORT OF THE CHEMICAL EXAMINATION OF WATER

Date - 21.04.25

NO. Lab/Tech(Chem)/2025

To,

Principal  
TAGORE PUBLIC SR. SEC. SCHOOL  
OSIAN, (JODHPUR)

District : JODHPUR  
Tehsil : OSIAN

Reference : spl/gis/  
Date of Receipt :

Dated  
Name of Sample Taker : Principal

Source	Bureau of Indian Standard (BIS) Drinking Water Standard (IS: 10500; 1991)		RO	-	-
Source			TAGORE PUBLIC SR. SEC. SCHOOL, Osian	-	-
Village / Town / City			Osian	-	-
Habitation				-	-
Village code no.	Maximum Desirable Limit	Maximum Permissible Limit		-	-
Date of collection				-	-
Date of examination				-	-
Lab. Sample no.			1078	-	-

Note :- All results except pH are in mg/L.

	pH	6.5 - 8.5		7.15	-	-
1						
2	Turbidity (NTU)	1	5	0	-	-
3	Temperature (°C)	-	-	24.2	-	-
4	Colour (Hazen Units)	Unobjectionable		None	-	-
5	Odour	Unobjectionable		U. 0.	-	-
6	Total alkalinity (as CaCO <sub>3</sub> )	200	600	70	-	-
7	Total Hardness (as CaCO <sub>3</sub> )	200	600	80	-	-
8	Calcium Hardness (as as CaCO <sub>3</sub> )	188	500	30	-	-
9	Magnesium Hardness (as as CaCO <sub>3</sub> )	125	417	50	-	-
10	Chloride (as Cl)	250	1000	60	-	-
11	Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	200	400	NA	-	-
12	Nitrite (as NO <sub>2</sub> )	-	-	NA	-	-
13	Nitrates (as NO <sub>2</sub> )	45	45	5	-	-
14	Fluoride (as F)	1.0	1.5	0.2	-	-
15	Total Dissolved Solids	500	2000	220	-	-
16	Iron	-	-	-	-	-
17	BOD (Bio chemical Oxygen Demand)	-	-	-	-	-

NA : - Not Analysed

*[Signature]*  
Junior Chemist 21.4.25  
PHED LAB JODHPUR  
Dated :

No. Lab / Teck (Chem)/2025  
Copy to:

*[Signature]*  
Junior Chemist  
PHED LAB JODHPUR